

Anatek Labs, Inc.

04 E Sprague Ave Ste D
Spokane WA 99202
(509) 838-3999 FAX 838-4433

1282 Alturas Drive
Moscow ID 83843
(208) 883-2839 FAX 882-9246

Turn Around Time Email Results Needed by: 4/21/17
 Normal Phone
 Mail Fax
 FAX # _____

Please fill out completely and legibly

Date Collected 4/11/17 Time Collected 1:30 PM County SPOKANE

Sample Purpose
 Purchase/Sale/Bldg Permit
 Informative
 New Well

Sample Type
 Standard Drinking Water
 Raw Source Water
 Other (Specify) _____

Owner or Manager Name
 KIM GREER

Specific Location Where Sample Was Collected (i.e. address of well)
 5508 W. MULE DEER LN
 DEER PARK

Send Report to:
 Name KIM GREER

Address 5007 E. CORAL LN

City SPOKANE St WA Zip 99223

Day Tel # 509 280-2151 Eve/Msg Tel # 509 535-1245

Sample Collected by: KIM GREER Company:

Source Type (Check One)
 Well/WellSpring Purchased or Intertie
 Spring Grd Water under Surface Influence
 Surface Water Combination or Other _____

COLIFORM BACTERIA (Lab Use Only)

SATISFACTORY (COLIFORM ABSENT)

REPEAT SAMPLES REQUIRED
 Unsatisfactory (Coliform Present)
 Total Present Total Absent
 E.Coli Present E.Coli Absent

Other Lab Results
 Total Coliform /100ml E.Coli /100ml
 Fecal Coliform /100ml Plate Count /100ml

Sample Not Tested Because: Sample Too Old Wrong Container Other _____
 Test Unsuitable Because: TNTC Turbid Culture Excess Debris

Report Date 4-12-17 Lab Analyst tlm
 Date Received 4-11-17 Time 11:00 By [Signature]

Inorganic Chemical Analysis Report

Tests	MCL	Results	Units	Compliance Y/N	Initials
✓ Arsenic (As)	0.01	<0.001	mg/L	Y	KNP
Barium (Ba)	2		mg/L		
Beryllium (Be)	0.004		mg/L		
Cadmium (Cd)	0.0005		mg/L		
Calcium (Ca)	-		mg/L		
Chloride (Cl)	250		mg/L		
Chromium (Cr)	0.1		mg/L		
Color	15		Color Units		
Conductivity	700		µmhos/cm 25°C		
Copper (Cu)	1.3		mg/L		
Corrosivity	-		-		
Cyanide (CN)	0.2		mg/L		
Fluoride (F)	4		mg/L		
Hardness	-		mg/L as CaCO ₃		
Iron (Fe)	0.3		mg/L		
✓ Lead (Pb)	0.015	<0.001	mg/L	Y	KNP
Magnesium (Mg)	-		mg/L		
Manganese (Mn)	0.05		mg/L		
Mercury (Hg)	0.002		mg/L		
Nickel (Ni)	0.1		mg/L		
✓ Nitrate as N	10	20.1	mg/L	YES	JB
Nitrite as N	0.5		mg/L		
pH	-		-		
Selenium (Se)	0.05		mg/L		
Silver (Ag)	0.05		mg/L		
Sodium (Na)	-		mg/L		
Sulfate (SO ₄)	250		mg/L		
TDS	500		mg/L		
TSS	-		mg/L		
Turbidity	1		NTU		
✓ Uranium (U)	30	<1	µg/L	Y	KNP
Zinc (Zn)	5		mg/L		

MCL-Max. Contaminant Level TSS-Total Suspended Solids TDS-Total Dissolved Solids

OTHER ANALYSES REQUESTED

Inorganic Contaminants (IOC's)	
Volatile Organics (VOC's)	
Semivolatile Organics (SOC's)	
Private Well Test	
Iron Bacteria	

Laboratory Comments pd cc 74852P
 BQA
 Lab Supervisor [Signature] Report Date 4-11-17

Anatek Log-in # 37090